

Family Name
Given Name
Student Number
Centre
Signature

with Answers.

4 December 2008

6077AC Electrical Systems Safety - Capstone Assessment

Time allowed – Three hours plus Ten minutes reading time

23 Pages in this Question Booklet

TOTAL MARKS AVAILABLE = 100

Aids to be supplied by college:

- None.

Aids to be supplied by student:

- Australian/New Zealand Wiring Rules AS/NZS 3000:2007.
- Australian/New Zealand Electrical Installations – Selection of Cables AS/NZS 3008.1.1:1998.
- NSW Service and Installation Rules.
- Students own marginal notes, indexing and formal amendments may be included in the above regulation books.
- Pen, pencil, eraser, rule, calculator.

Section	Possible Mark	Actual Mark
A	15	
B	20	
C	46	
D	19	
TOTAL	100	

Instructions to student:

- Mobile phones are to be turned off and removed from your person. You cannot access a mobile phone during this test.
- All questions to be answered in the space provided on this **Examination Paper**. Answers to Section A – Multi-choice Questions, are to be recorded on the Answer Sheet on Page 23 of this **Question Booklet**.
- You are not to use any other reference book in this examination.
- The whole of this paper is to be handed to the Supervisor upon completion.
- All Questions to be attempted.

Aids permitted where indicated:

Standard Dictionaries	Bilingual Dictionaries	Technical Dictionaries	Programmable Calculators	Non-programmable Calculators	Electronic Devices
No	No	No	No	Yes	No

- (a) 3 m
- (b) 4.5 m
- (c) 5.5 m
- (d) Not permitted

What is the minimum clearance for bare live aerial conductors above a swimming pool?

QUESTION 5. (1 Mark)

- (a) 90 °C
- (b) 160 °C
- (c) 75 °C
- (d) 250 °C

Under short circuit conditions, what is the maximum permissible sheath temperature for a 25 mm^2 XLPE (X 90) Cu single core cable?

QUESTION 4. (1 Mark)

- (a) 5 % of U_{no}
- (b) 11.5 Volts
- (c) 5 % of the voltage measured at the MSB
- (d) 10 % of the nominal supply voltage

The maximum permissible voltage drop between the point of supply and any point in a 400 V electrical installation is:

QUESTION 3. (1 Mark)

- (a) 1
- (b) 2
- (c) 3
- (d) Unlimited

In a domestic installation, the maximum number of final sub circuits that can be supplied from a single RCD is:

QUESTION 2. (1 Mark)

- (a) IN
- (b) IZ
- (c) ISC
- (d) IB

The term used in AS3000 to describe the current carrying capacity of a cable is:

QUESTION 1. (1 Mark)

INSTRUCTIONS: Select the best answer for the following statements and place an 'X' in the appropriate box on the Answer Sheet attached to this Examination Paper.

SECTION A. (15 Marks)

QUESTION 6. (1 Mark)

A cable / wiring system suitable for installation in a high temperature environment would be:

- (a) Unenclosed TPS cable
- (b) TPS cable enclosed in non-metallic conduit
- (c) Unenclosed bare MIMS cable
- (d) Unenclosed TPI cable

QUESTION 7. (1 Mark)

What is an acceptable level of leakage current for a 230 V class I appliance?

- (a) 30 mA
- (b) 10 mA
- (c) 0.5 mA
- (d) 0.22 mA

QUESTION 8. (1 Mark)

The main neutral installed in a 400 / 230 V MEN installation consisting of predominately balanced three phase loads:

- (a) Can be reduced to 33.3 % of the main active conductors CSA
- (b) Must have the same CSA as the main active conductors
- (c) Must not be less than 50 % of the main active conductors CSA
- (d) Must have a minimum current carrying capacity of 100 A

QUESTION 9. (1 Mark)

Underwater pool lighting must be supplied with a / an:

- (a) Earthing conductor connected to the light
- (b) PELV system installed close to the light
- (c) PELV or SELV system supply of 12 V AC or less
- (d) SELV system not exceeding 30 V AC

QUESTION 10. (1 Mark)

What is the maximum allowable resistance of an equipotential bonding conductor?

- (a) Not specified
- (b) 0.5Ω
- (c) 1Ω
- (d) 2Ω

- (a) Be lower than the current for which the circuit is designed (IB)
 (b) Be equal to or greater than the circuit breaker nominal rating (IN)
 (c) Be greater than the current to be carried by the conductor
 (d) Be based on an ambient air temperature of 45 °C

Every conductor shall have a current-carrying capacity that must:

QUESTION 15. (1 MARK)

- (a) Unspecified
 (b) 100 ms
 (c) 400 ms
 (d) 5 s

The maximum disconnection time specified for protection against indirect contact for a Sub Main is:

QUESTION 14. (1 MARK)

- (a) Consumer
 (b) Licensed installing electrician
 (c) Licensed electrician who completed the test
 (d) Installation inspector

A Certificate of Compliance should be finalised when an electrical installation is tested and should be completed by the:

QUESTION 13. (1 MARK)

- (a) 12
 (b) 15
 (c) 20
 (d) Not specified

The maximum number of lighting points that can be connected to a circuit wired in 1.0 mm² TPS cable and protected by a 6 A type C CB is:

QUESTION 12. (1 MARK)

- (a) AS2381
 (b) AS2209
 (c) AS3017
 (d) All of the above

With which standard must equipment installed in a hazardous area comply?

QUESTION 11. (1 MARK)

Marks

SECTION B. (20 Marks)

INSTRUCTIONS: In this part of the assessment, you are required to answer a range of questions by using AS/NZS 3000.2007. For each question, you are required to supply an answer to the question, and the clause from AS/NZS 3000.2007 that relates to the answer. This section contains ten questions for a total of twenty marks.

QUESTION 1. (2 Marks)

- 1 What is the maximum disconnection time for a final sub circuit supplying portable equipment intended to be moved during use?

.....
.....

- 1 AS/NZS 3000 Reference (Clause number)

QUESTION 2. (2 Marks)

- 1 Is it necessary to provide an equipotential bond to a conductive water pipe that is not accessible from within a building?

.....

- 1 AS/NZS 3000 Reference (Clause number)

QUESTION 3. (2 Marks)

- 1 What are the requirements for earthing a switchboard surround that is supplied by unprotected consumers' mains?

.....
.....
.....

- 1 AS/NZS 3000 Reference (Clause number)

QUESTION 4. (2 Marks)

- 1 List three acceptable sources for an isolated (separated) supply.

.....
.....
.....

- 1 AS/NZS 3000 Reference (Clause number)

1 AS/NZS 3000 Reference (Clause number)

.....

1 Identify an acceptable method used to determine maximum demand of a final sub circuit consisting of 10 A socket outlets.

QUESTION 7. (2 Marks)

1 AS/NZS 3000 Reference (Clause number)


.....

1 A sink has a capacity < 45 litres. List the minimum required IP rating for a luminaire installed within Zone 2.

QUESTION 6. (2 Marks)

1 AS/NZS 3000 Reference (Clause number)

.....



1 When terminating a stranded conductor, is it acceptable to twist and place the conductors under a washer as depicted below? List AS3000 requirements.

QUESTION 5. (2 Marks)

Marks

Marks

QUESTION 8. (2 Marks)

- 1** Is it permissible to complete an addition to an existing final sub circuit consisting of unprotected 10 A socket outlets, without installing RCD protection?

.....
.....
.....

- ## **1 AS/NZS 3000 Reference (Clause number**

QUESTION 9. (2 Marks)

- 1 List five criteria that need to be addressed when designing an electrical installation.

.....
.....
.....
.....
.....

- ## 1 AS/NZS 3000 Reference (Clause number


QUESTION 10. (2 Marks)

- 1** What are the requirements when installing a common neutral?

A set of four horizontal lines, each consisting of a series of small dots. The lines are evenly spaced and extend across the width of the page.

- ## 1 AS/NZS 3000 Reference (Clause number

(Continued on the next page.)

**QUESTION 1. (4 Marks)**

INSTRUCTIONS: This section involves calculations. Show all necessary working in the space provided, marks will be awarded accordingly. Answers are to be highlighted or underlined.

SECTION C. (46 Marks)

Marks

QUESTION 1. (Cont'd)

- 1 (a) Determine the phase impedance of the transformer.

.....
.....
.....
.....
.....
.....

- 1 (b) Assuming the transformer has a phase impedance of $7 \text{ m}\Omega$, determine the maximum 3 ϕ prospective short circuit current at the POS (point A), (AS3008 has appropriate tables to determine conductor resistance – ignore conductor reactance).


.....
.....
.....
.....
.....
.....

- 1 (c) Determine the system impedance, for a 3 ϕ prospective fault current of 12 kA at point 'C' the Sub Board.

.....
.....
.....
.....
.....
.....


- 1 (d) If the Active Earth fault current is 4.5 kA at the SB (point C), determine the maximum earth fault current at the end of the final sub circuit (assume all fault current flows back through MEN at MSB and SB has no MEN connection).

.....
.....
.....
.....
.....
.....



Determine the minimum size cable for the SINGLE PHASE final sub circuit, based on Current Carrying Capacity.

QUESTION 3. (4 Marks)




Determine the minimum size cable for the SINGLE PHASE final sub circuit, based on Voltage Drop.

QUESTION 2. (4 Marks)

QUESTION 4. (4 Marks)

Determine if the final sub circuit satisfies the requirements for fault loop impedance – show all references and workings.



QUESTION 5. (4 Marks)

Determine the maximum demand for the following 230 V SINGLE Domestic Installation:

- 34 x 50 W down lights
- 17 x double 10 A socket outlets
- 5 x single 10 A socket outlets
- 1 x 5 kW 230 V cooktop
- 1 x 4 kW 230 V oven
- 1 x 15 A socket outlet (general purpose)
- 1 x 20 A socket outlet for 230 V 16 A air conditioner
- 4 x permanently connected 120 W ceiling fans
- 2 x 10 A socket outlets installed > 2.4 m for 75 W exhaust fans

(Continued on the next page.)

	Maximum Demand
Load Group	No of Points / Load Calculation
Ai	
Aii	
Bi	
Bii	
Biii	
C	
D	
E	
F	
G	

QUESTION 5. (Cont'd)

QUESTION 6. (7 Marks)

Determine the maximum demand for the following 400 / 230 V three-phase MULTIPLE domestic installation, consisting of thirty individual living units.

Electrical equipment associated with each individual (1) unit:

- 18 x 50 W down lights
- 10 x double 10 A socket outlets
- 3 x single 10 A socket outlets
- 1 x 10 A socket outlet for 230 V air conditioner
- 2 x permanently connected 120 W ceiling fans

In addition to the load above, six of the units have the following electrical loads:

- 1 x 5 kW 230 V cooktop
- 1 x 4 kW 230 V oven
- 1 x 4.8 kW electric storage hot water system

The following communal load is also installed:

- 30 x 230 V 100 W bollards (balanced equally across each phase)
- 9 x 230 V 250 W 4 A Metal Halide outdoor lighting (three circuits)
- 8 x double 10 A single phase socket outlets (two circuits)

(Continued on the next page.)


Load Group	No of Points / Load	Calculation	Red	White	Blue	Maximum Demand
M						
L						
K						
JHi						
JH						
Jf						
I						
H						
G						
F						
E						
D						
C						
Bii						
Bil						
Bi						
Aii						
Ai						

Use only the required load groups in the table below.

QUESTION 6. (Cont'd)


QUESTION 7. (3 Marks)


Using the diagram above, determine the current carrying capacity of the THREE phase 4 mm² multi-core Cu V 90 cable, which is installed flat on a perforated cable tray spaced from one other similar circuit.



QUESTION 8. (4 Marks)

A 400 V three phase final sub circuit supplying a socket outlet is to be wired with 4 mm² X 90 four-core and earth cable. The circuit is protected by a 32 A, type C circuit breaker. The voltage measured at the Sub Board is 391 V. In order to comply with AS/NZS 3000 regarding voltage drop, what is the maximum allowable route length of the circuit?





A three pole 100 A type 'C' circuit breaker will protect the circuit.

A 400 V THREE phase consumer main is to be enclosed in three single HD PVC conduits that will be installed touching underground at a depth of 600 mm. The ambient soil temperature is 20°C . The circuit will be wired with 4 x single core X 90 Cu cables.


QUESTION 9. (5 Marks)

QUESTION 10. (7 Marks)

Determine the maximum demand for the following 400 V FACTORY Installation:

- 10 x double 10 A socket outlets
- 6 x hi bay metal halide lamps @ 3.5 A each
- 30 x fluorescent lamps @ 0.4 A each
- 3 x 20 A three phase socket outlets
- 3 x 15 A three phase socket outlets
- 2 x 400 V single phase welders @ 20 A each
- 2 x 25 A single phase motors

Load Group	Points / Load	Calculation	Red	White	Blue
A					
Bi					
Bii					
Biii					
C					
D					
E					
F					
G					
H					
Maximum Demand					



The following diagram shows a main switch board in a domestic installation. The consumer mains include an active, neutral and main earth from the electricity supply. The installation condition of all final sub circuits is fully surrounded by thermal insulation. There are four final sub circuits supplying socket outlets, wired with 2.5 mm², multi-core, V 90, Cu cables. It has been determined to use separate RCD's to provide the required earth leakage protection for the circuits. Complete all necessary active, neutral and earth connections for these four final sub circuits on the wiring diagram below, ensuring the connection complies with AS/NZS 3000.2007 and AS/NZS 3008.1.1:1998.


QUESTION 1. (5 Marks)

INSTRUCTIONS: The questions in this section require some simple drawing. Ensure that the drawing is neat and legible. The use of pencil on the drawing is acceptable in this section only.

SECTION D - (19 Marks)

QUESTION 2. (4 Marks)

A 20 A type C circuit breaker with the following tripping characteristic is protecting a 230 V circuit wired with 2.5 mm^2 , multi-core, V 90, Cu cable. The circuit is supplying socket outlets. The fault loop impedance was measured at the extreme point on the circuit using a fault loop impedance instrument. The result was 1.6Ω at ambient conditions (i.e. 40°C). Answer the questions below. Show all working, and support your answer/s by marking the characteristic curve below.



- (a) Calculate the fault current for an active to earth fault at the extreme point.
-
.....


- (b) Determine the circuit breaker trip time using the fault condition indicated above.
-

- (c) Does the circuit meet AS/NZS 3000 requirements for fault loop impedance? Why?

YES / NO

- (e) Determine the maximum allowable resistance of the protective earth conductor.
-

- The main neutral should be:
- (a) Connected to Position 1
(b) Disconnected as shown in position 2
- The leads of the testing device are:
- (a) Correctly connected
(b) Incorrectly connected
- A reading of 0.9 MΩ would indicate:
- (a) A fault
(b) No fault
- The MEN link should be:
- (a) Connected to position 1
(b) Disconnected as shown in position 2
- The leads of the testing device are:
- (a) Correctly connected
(b) Incorrectly connected as shown in position 2




The following diagram shows how the switchboard has been prepared, ready for testing the insulation resistance between active and earth of a single-phase lighting circuit. The circuit is protected by a 6 A combined RCD / MCB. The lighting circuit has loads with dimmer control. Identify the correct setting for the insulation resistance tester by placing an 'X' in the appropriate box and answer the four questions. The board is electrically isolated.

QUESTION 3. (4 Marks)

QUESTION 4. (4 Marks)

Answer the question and complete the following table using the diagram below. A correct circuit connection test is being performed. Identify the correct setting for the test equipment by placing an 'X' in the appropriate box. The board is electrically isolated.



- (a) Assuming the socket outlet is correctly connected, complete the table:

Test Equipment Connection	Reading
Earth to Active with socket outlet switch off	
Earth to Active with socket outlet switch on	
Earth to Neutral with socket outlet switch off	
Earth to Neutral with socket outlet switch on	

- (b) Identify any fault indicated by a reading of 5 Ohms between the active and earth socket measured at the socket outlet:
-

maximum capacity of through sockets available.
Load and socket-outlet spacing factors (load and socket-outlet spacing applications may be combined
equivalent should be substituted).
circuits which is shown the socket-outlets may be used for specific items of electrical equipment such as dishwashers, from hobs or cookers etc. the actual load of the
the outlets are intended to be limited when the total load of the
and installed more than 2.3 m above a floor or 2.3 m above a roof.
load of the connection of a lighting point or appliance rated at not more than 150 W
conductors having a cross-sectional area less than 2.5 mm², except where they are
resistorive conductances Table G5 specifies the connection of any socket-outlets to a
outlets with a separate circuit breaker connected APPLIES where there are two or more
be connected to a single point.
an appropriate rated at not more than 150 W which is permanently connected, or
connected by means of a socket-outlet installed more than 2.3 m above a floor, may
be substituted as a lighting point.
A socket-outlet installed more than 2.3 m above a floor or the connection of a
resistorive load having points. See Table C1 for the maximum
connection of resistive load to the number of outlets in which it is switched on the
according to the number of points it connects to the circuit breaker by which it is controlled.
switching points A number is deemed to comprise of those which are made by switching points
switching points A number is limited by the range of terminals and terminals
or diversity in operation of the range of terminals and terminals
minimum demand is limited by the circuit-breaker rating applicable to the final subcircuit which always
3000.
A suitable and over size conductor to be run circuit-breaker mounted within one
socket-outlets in the subcircuit.
socket-outlets is regarded as the same number of points as the number of (single)
for the purpose of determining the number of points a suitable combination of
outlets may make the connection impractical.
lighting points on these standards does not preclude the provision of the terminals of these
supplementary power outlets for domestic purposes, where breakers and switches and
ranges. While this standard does not permit the connection of socket-outlets and
fuses for 6 mm² and 10 mm² conductors to the given number of domestic outlets
Table G5 for a three-phase circuit installed in the normal installation of fuses
cable used in connection with a 20 A protective device is recommended for use in
insulation mechanical stress and protective device ratings below acceptably to specific
cable cross-sectional areas and protective device ratings below acceptably to specific
notes to table G8

NOTES TO TABLE G8

(continued)									
Cable cross-sectional area (mm ²)	Rating of circuit-breaker (A)	Guidance on the loading of points per final subcircuit							
		Contracture of each point (A)							
Maximum connected load (W)									
1	6	0.5	NP						
1	10	0.5	NP						
1	13	0.5	NP						
1	16	0.5	NP						
1.5	8	0.5	NP						
1.5	10	0.5	NP						
1.5	13	0.5	NP						
1.5	16	0.5	NP						
2	13	0.5	NP						
2	16	0.5	NP						
2	20	0.5	NP						
2.5	10	0.5	NP						
2.5	13	0.5	NP						
2.5	16	0.5	NP						
2.5	20	0.5	NP						
3	13	0.5	NP						
3	16	0.5	NP						
3	20	0.5	NP						
4	16	0.5	NP						
4	20	0.5	NP						
5	20	0.5	NP						
5	25	0.5	NP						
6	25	0.5	NP						
7	25	0.5	NP						
8	25	0.5	NP						
9	25	0.5	NP						
10	25	0.5	NP						
11	25	0.5	NP						
12	25	0.5	NP						
13	25	0.5	NP						
14	25	0.5	NP						
15	25	0.5	NP						
16	25	0.5	NP						
17	25	0.5	NP						
18	25	0.5	NP						
19	25	0.5	NP						
20	25	0.5	NP						
21	25	0.5	NP						
22	25	0.5	NP						
23	25	0.5	NP						
24	25	0.5	NP						
25	25	0.5	NP						
26	25	0.5	NP						
27	25	0.5	NP						
28	25	0.5	NP						
29	25	0.5	NP						
30	25	0.5	NP						
31	25	0.5	NP						
32	25	0.5	NP						
33	25	0.5	NP						
34	25	0.5	NP						
35	25	0.5	NP						
36	25	0.5	NP						
37	25	0.5	NP						
38	25	0.5	NP						
39	25	0.5	NP						
40	25	0.5	NP						
41	25	0.5	NP						
42	25	0.5	NP						
43	25	0.5	NP						
44	25	0.5	NP						
45	25	0.5	NP						
46	25	0.5	NP						
47	25	0.5	NP						
48	25	0.5	NP						
49	25	0.5	NP						
50	25	0.5	NP						
51	25	0.5	NP						
52	25	0.5	NP						
53	25	0.5	NP						
54	25	0.5	NP						
55	25	0.5	NP						
56	25	0.5	NP						
57	25	0.5	NP						
58	25	0.5	NP						
59	25	0.5	NP						
60	25	0.5	NP						
61	25	0.5	NP						
62	25	0.5	NP						
63	25	0.5	NP						
64	25	0.5	NP						
65	25	0.5	NP						
66	25	0.5	NP						
67	25	0.5	NP						
68	25	0.5	NP						
69	25	0.5	NP						
70	25	0.5	NP						
71	25	0.5	NP						
72	25	0.5	NP						
73	25	0.5	NP						
74	25	0.5	NP						
75	25	0.5	NP						
76	25	0.5	NP						
77	25	0.5	NP						
78	25	0.5	NP						
79	25	0.5	NP						
80	25	0.5	NP						
81	25	0.5	NP						
82	25	0.5	NP						
83	25	0.5	NP						
84	25	0.5	NP						
85	25	0.5	NP						
86	25	0.5	NP						
87	25	0.5	NP						
88	25	0.5	NP						
89	25	0.5	NP						
90	25	0.5	NP						
91	25	0.5	NP						
92	25	0.5	NP						
93	25	0.5	NP						
94	25	0.5	NP						
95	25	0.5	NP						
96	25	0.5	NP						
97	25	0.5	NP						
98	25	0.5	NP						
99	25	0.5	NP						
100	25	0.5	NP						
101	25	0.5	NP						
102	25	0.5	NP						
103	25	0.5	NP						
104	25	0.5	NP						
105	25	0.5	NP						
106	25	0.5	NP						
107	25	0.5	NP						
108	25	0.5	NP						
109	25	0.5	NP						
110	25	0.5	NP						
111	25	0.5	NP						
112	25	0.5	NP						
113	25	0.5	NP						
114	25	0.5	NP						
115	25	0.5	NP						
116	25	0.5	NP						
117	25	0.5	NP						
118	25	0.5	NP						
119	25	0.5	NP						
120	25	0.5	NP						
121	25	0.5	NP						
122	25	0.5	NP						
123	25	0.5	NP						
124	25	0.5	NP						
125	25	0.5	NP						

NEW SOUTH WALES
DEPARTMENT
OF EDUCATION
AND TRAINING



Family Name
Given Name
Student Number
Centre
Signature

4 December 2008

6077AC Electrical Systems Safety - Capstone Assessment

ANSWER SHEET – Section A. (Multi-choice Questions)

Instructions:

- Enter your personal details on this sheet.
- Place an X in box of your choice. If you make a mistake- circle your answer and choose again.
- For your convenience you can remove this page while you answer Section A. Remember to re-attach it to the paper when you hand it in.

Question	a	b	c	d
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				
11				
12				
13				
14				
15				
Totals				
Total Correct Section A				

Total Marks Section A: /15

END OF EXAMINATION

Total Marks Section A: /15

END OF EXAMINATION

- Reflexion AS/NZS 3000
B3.2.1 Electrical Z.1
2.6.2.4 (a)
3.6.2
T52 - AS/NZS 3008.1
T3.8
General Knowledge
3.5.2
G.3.4.5(c)(iii) A,B,C
7.4.7.4
Appendix A
General Knowledge
B4.3
B3.2.1 Electrical Z.1

Question	a	b	c	d	Total Correct Section A		
	Totals	2	4	4	3		
1	X						
2		X					
3		X					
4			X				
5				X			
6					X		
7						X	
8							X
9							X
10			X				
11			X				
12				X			
13		X					
14				X			
15					X		

- Enter your name and college on this sheet.
- Place an X in box of your choice. If you make a mistake - circle your answer and choose again.
- For your convenience you can remove this page while you answer Section A. Remember to re-attach it to the paper when you hand it in.

Instructions:

Module - 6077AC Examination Date: 4th December 2008

ANSWER SHEET - Section A (Multi-choice Questions)

College:.....

Name:.....

SECTION A – (15 Marks)

INSTRUCTIONS: Select the best answer for the following statements and place an 'X' in the appropriate box on the Answer Sheet attached to this examination paper. Each correct answer is worth ONE (1) mark.

QUESTION 1. (1 Mark)

The term used in AS3000 to describe the current carrying capacity of a cable is:

- (a) I_N
- (b) I_z
- (c) I_{sc}
- (d) I_B

QUESTION 2. (1 Mark)

In a domestic installation, the maximum number of final sub circuits that can be supplied from a single RCD is:

- (a) 1
- (b) 2
- (c) 3
- (d) unlimited

QUESTION 3. (1 Mark)

The maximum permissible voltage drop between the point of supply and any point in a 400V electrical installation is:

- (a) 5% of U_o
- (b) 11.5 Volts
- (c) 5% of the voltage measured at the MSB
- (d) 10% of the nominal supply voltage

QUESTION 4. (1 Mark)**SECTION A - (Cont'd)**

Under short circuit conditions, what is the maximum permissible sheath temperature for a 25mm^2 XLPE (X90) Cu single core cable?

- (a) 90°C
- (b) 160°C
- (c) 75°C
- (d) 250°C

QUESTION 5. (1 Mark)

What is the minimum clearance for bare live aerial conductors above a swimming pool?

- (a) 3 m
- (b) 4.5 m
- (c) 5.5 m
- (d) not permitted

QUESTION 6. (1 Mark)

A cable/wiring system suitable for installation in a high temperature environment would be

- (a) unenclosed TPS cable
- (b) TPS cable enclosed in non-metallic conduit
- (c) unenclosed bare MIMS cable
- (d) unenclosed TPI cable

QUESTION 7. (1 Mark)

What is an acceptable level of leakage current for a 230V class I appliance?

- (a) 30 mA
- (b) 10 mA
- (c) 0.5 mA
- (d) 0.22 mA

SECTION A – (Cont'd)

QUESTION 8. (1 Mark)

The main neutral installed in a 400/230V MEN installation consisting of predominately balanced three phase loads:

- (a) can be reduced to 33.3% of the main active conductors CSA
- (b) must have the same CSA as the main active conductors
- (c) must not be less than 50% of the main active conductors CSA
- (d) must have a minimum current carrying capacity of 100A

QUESTION 9. (1 Mark)

Underwater pool lighting must be supplied with a/an

- (a) earthing conductor connected to the light
- (b) PELV system installed close to the light
- (c) PELV or SELV system supply of 12V AC or less
- (d) SELV system not exceeding 30V AC

QUESTION 10. (1 Mark)

What is the maximum allowable resistance of an equipotential bonding conductor?

- (a) not specified
- (b) 0.5Ω
- (c) 1Ω
- (d) 2Ω

QUESTION 11. (1 Mark)

With which standard must equipment installed in a hazardous area comply?

- (a) AS2381
- (b) AS2209
- (c) AS3017
- (d) all of the above

(End of Section A)

- (a) be lower than the current for which the circuit is designed (IB)
- (b) be equal to or greater than the circuit breaker nominal rating (IN)
- (c) be greater than the current to be carried by the conductor
- (d) be based on an ambient air temperature of 45°C

Every conductor shall have a current-carrying capacity that must

QUESTION 15. (1 Mark)

- (a) unspecified
 - (b) 100 ms
 - (c) 400 ms
 - (d) 5s
- The maximum disconnection time specified for protection against indirect contact for a Sub Main is

QUESTION 14. (1 Mark)

- (a) consumer
 - (b) licensed installing electrician
 - (c) licensed electrician who completed the test
 - (d) installation inspecotor
- A Certificate Of Compliance should be finalised when an electrical installation is tested and should be completed by the

QUESTION 13. (1 Mark)

- (a) 12
- (b) 15
- (c) 20
- (d) not specified

The maximum number of lighting points that can be connected to a circuit wired in 1.0 mm^2 TPS cable and protected by a 6A type C CB is

QUESTION 12. (1 Mark)

SECTION A - (Cont'd)

SECTION B – (20 Marks)

INSTRUCTIONS: Blank spaces in the following statements represent omissions. Write the appropriate word, words or information in the numbered spaces provided. Each question is worth TWO (2) marks.

- Use AS/NZS 3000:2007 to best answer each question.
- Write clause or table numbers where required.

QUESTION 1.

What is the maximum disconnection time for equipment intended to be touched?

0.45

AS/NZS 3000 Reference

5.7.2 Disconnection times

also

1-5.5.3(d)(c)

The maximum disconnection time for a 230 V supply voltage shall not exceed the following:

- 0.4 s for final subcircuits that supply—
 - socket-outlets having rated currents not exceeding 63 A; or
 - hand-held Class I equipment; or
 - portable equipment intended for manual movement during use.
- 5 s for other circuits where it can be shown that people are not exposed to touch voltages that exceed safe values.

NOTES:

- 1 Maximum disconnection times will vary for other operating voltages or installation conditions, such as wet locations, etc.
- 2 The fault current must be of sufficient magnitude to cause automatic disconnection within the required times.

QUESTION 2.

Is it necessary to provide conductive water piping that is both—

No

AS/NZS 3000 Reference

5.6.2.2 Conductive water piping

Conductive water piping that is both—

- installed and accessible within the building containing the electrical installation; and
- continuously conductive from inside the building to a point of contact with the ground,

shall be bonded to the earthing system of the electrical installation.

Any equipotential bonding of conductive water piping shall be effected by means of an equipotential bonding conductor connected to the main earthing conductor or earth terminal or bar.

The connection of the bonding conductor to the conductive water piping shall be as close as practicable to the entry of the conductive water piping to the building.

QUESTION 3.

What are the requirements for earthing a switchboard surround that is supplied by unprotected consumers mains

Same size

as the main

neutral conductor

AS/NZS 3000 Reference

5.5.3.5 Unprotected consumers mains

Exposed conductive parts associated with consumers mains not provided with short-circuit protection on the supply side shall be earthed by a conductor with a current-carrying capacity not less than that of the main neutral conductor.

This conductor shall be connected to—

- the main neutral conductor or bar; or
- the main earthing terminal/connection or bar, in which case, in accordance with Clause 5.3.5.2, the cross-sectional area of the MEN connection shall be not less than that of the main neutral conductor.

AS/NZS 3000 Reference (Clause number)

IPX4

A sink has a capacity <45 litres. This luminaire is installed within Zone 2

QUESTION 6.


AS/NZS 3000 Reference (Clause number)

GUIDANCE ON THE SELECTION FOR BATHS, SHOWERS
AND OTHER FIXED WATER CONTAINERS

TABLE 6.1

3.7.2.5 Relocation of stranded conductors
The ends of stranded conductors shall be secured by suitable means, so as to prevent the spread of individual strands. They shall not be soft-soldered before clamping under a screw or between metal surfaces.

No



When terminating a stranded conductor, is it acceptable to twist and place the conductors under a washer as depicted below? List AS3000 requirements.

QUESTION 5.

AS/NZS 3000 Reference (Clause number)

(a) An isolating transformer complying with AS/NZS 61558 so that the output is separated from the input by double insulation or equivalent, or a generator output, e.g. a motor-generator set that is installed so that a generator output is separated from the frame of the generator; or

(b) The source supplying a separated circuit shall be—

(c) An isolated inverter complying with the safety requirements of AS/NZS 4763 (Int).

NOTE: The fitting of an RCD, and the connection of an equipotential bonding conductor and an additional conductor to the RCD, does NOT provide the output separation required by this Clause. See AS/NZS 3010 for details.

NOTE: The fitting of an RCD, and the connection of the generator output to ensure the correct operation of the RCD, does NOT provide the output separation required by this Clause. See AS/NZS 3010 for details.

QUESTION 4.

List three acceptable sources for an isolated (separated) supply

SECTION B - (Cont'd)

SECTION B – (Cont'd)

QUESTION 7.

Identify an acceptable method
circuit consisting of 10A socket

Assessment

Limitation

C2.5 Maximum demand in final subcircuits also 2.2.2(a) b) c) d).

C2.5.1 General

The maximum demand in final subcircuits is determined—

- (a) for single items of equipment, by assessment of the connected load; or
- (b) for multiple items of equipment, by limitation of the current rating of a circuit-breaker.

In some applications, the connected equipment may operate in a particular manner that allows for diversity to be applied. This includes welding machines (see Paragraph 2.5.2), domestic cooking appliances (Paragraph C2.5.3) and interlocked equipment (Paragraph C2.5.4)

AS/NZS 3000 Reference (Clause number _____)

QUESTION 8.

Is it permissible to complete an addition to an existing final sub circuit consisting of unprotected 10A socket outlets, without installing RCD protection?

No

1.9.3 Alterations, additions and repairs and 2.6.3-4

Every alteration of, or addition to, an existing electrical installation shall be deemed to be a new electrical installation, and all relevant provisions of this Standard shall apply to every such alteration or addition.

Additions, alterations or repairs to an existing installation constructed to a Part 1 design and installation solution shall not alter the compliance of the existing installation with Part 1.

Alterations or additions to an existing electrical installation shall not cause any portion of the original electrical installation, or electrical equipment connected thereto, to—

- (a) carry currents or sustain voltages in excess of those permitted by this Standard; or
- (b) be used in any manner that is not in accordance with this Standard.

Repairs to existing electrical installations or parts thereof may be effected using methods that were acceptable when that part of the electrical installation was originally installed, provided that the methods satisfy the fundamental safety principles of Part 1 of this Standard.

AS/NZS 3000 Reference (Clause number _____)

QUESTION 9.

List five criteria that need to be addressed when designing an electrical installation.

1.6 DESIGN OF AN ELECTRICAL INSTALLATION

1.6.1 General

An electrical installation shall be designed to—

- (a) protect persons, livestock and property from harmful effects;
- (b) function correctly as intended;
- (c) connect, operate safely and be compatible with the electricity distribution system, or other source of supply, to which the electrical installation is to be connected;
- (d) minimize inconvenience in the event of a fault; and
- (e) facilitate safe operation, inspection, testing and maintenance.

AS/NZS 3000 Reference (Clause number _____)

SECTION B - (Cont'd)**QUESTION 10.****List the requirements when installing a common neutral?**

2.2.1.2 Common neutral	Each single-phase circuit, and each multiphase circuit that requires a neutral conductor for the operation of connected equipment, shall incorporate a neutral conductor.
	A common neutral conductor may be used for two or more circuits subject to the following conditions:
	(a) The continuity of the common neutral conductor shall not depend on connections at the terminals of electrical equipment, including control breakers.
	(b) The circuits shall be controlled and protected by linked circuit switches.
	(c) The neutral conductor shall be marked at the switchboard to identify breakers.


AS/NZS 3000 Reference (Clause**A150 Clause 29.5.5**


NOTES:	
	1 Typical applications for common neutrals include groups of single-phase fittings arranged across supply, and separate components of a single-phase assembly, such as a cooking unit
	2.9.5.5
	3
	4

SECTION C – (46 Marks)



INSTRUCTIONS: This section involves calculations. Show all necessary working in the space provided, marks will be awarded accordingly. Answers are to be highlighted or underlined.

QUESTION 1. (4 Marks)







Cable installation method



QUESTION 3. (4 Marks)



Determine the minimum size cable for the SINGLE PHASE final sub circuit, based on Voltage Drop.



SECTION C - (Cont'd)

Corrected page
from Set 2

24/10/2008

- a) Determine the phase impedance of the transformer.

1 Mark	$I_{fl} = \frac{S}{\sqrt{3}V}$ $= \frac{500,000}{693}$ $= 722 \text{ A}$	$I_{sc} = 100 I_{fl}$ $\%z$ $= \frac{72,200}{4.23}$ $= 17.1 \text{ kA}$	$Z_{ph} = \frac{U_{ph}}{I_{sc}}$ $= \frac{230}{17100}$ $= 13.5 \text{ m}\Omega$	$Z_{Tx} = 0.01348 \Omega$
---------------	--	--	---	---------------------------

$$S = \sqrt{3} V I \quad \therefore I = \frac{S}{\sqrt{3} V}$$

- b) Assuming the transformer has a phase impedance of $7 \text{ m}\Omega$, determine the maximum 3ϕ prospective short circuit current at the P.O.S. (point A). (AS3008 has appropriate tables to determine conductor resistance – ignore conductor reactance)

1 Mark	$I_{sc} = \frac{U_{ph}}{Z_{fl}}$ $= \frac{230}{0.007 + 0.0046z}$ $= 19793 \text{ A}$ $= 19.8 \text{ kA}$	AS3008 Table 34 $85\text{m } 500\text{mm}^2 \times 90 \text{ Cu}$ $= \frac{0.0538 \times 85}{1000}$ $= 4.62 \text{ m}\Omega \quad 4.573 \text{ m}\Omega$	Ref T34 Single Core $500\text{mm}^2 \times 90$ 0.538Ω	$I_{sc} = 19.8 \text{ kA}$
---------------	---	---	---	----------------------------

- c) Determine the system impedance, for a 3ϕ prospective fault current of 12 kA at point "C" the Sub Board.

1 Mark	$Z_{ph} = \frac{U_{ph}}{I_{sc}}$ $= \frac{230}{12000}$ $= 19.2 \text{ m}\Omega$	$Z_{system} = 0.0192 \Omega$
---------------	---	------------------------------

- d) If the Active Earth fault current is 4.5 kA at the SB (point C), determine the maximum earth fault current at the end of the final sub circuit. (Assume all fault current flows back through MEN at MSB and SB has no MEN connection)

1 Mark	$Z_{ph} = \frac{U_{ph}}{I_{sc}}$ $= \frac{230}{4500}$ $= 51.1 \text{ m}\Omega$	$I_{sc} = \frac{U_{ph}}{Z_{fl}}$ $= \frac{230}{0.051 + 0.52}$ $= 402 \text{ A}$	AS3008 Table 35 $29\text{m } 2.5\text{mm}^2 \times 90 \text{ Cu}$ $= \frac{9.01 \times 29}{1000}$ $= 0.26 \Omega \times 2 (R_{ph}+R_{pe})$ $= 0.52 \Omega$	$I_{sc} = 402 \text{ A}$
---------------	--	---	--	--------------------------


FOR MAXIMUM FAULT CURRENT

* NOTE: Answers may vary if the temperature is 45°C *



SECTION C – (Cont'd)

QUESTION 4. (4 Marks)



Determine if the final sub circuit satisfies the requirements for fault loop impedance – show all references and working

AS3000.2007 Disconnection time 0.4s Unable to use Table B1	From AS3000.2007 Appendix B5.2.2 $\rho=0.0225$ Appendix B4.5 $I_a=16 \times 7.5$ $I_a = 120$	$L_{max} = \frac{0.8U_o Sph Spe}{I_a (Sph+Spe)}$ $L_{max} = \frac{0.8 \times 230 \times 6 \times 2.5}{120 \times 0.0225 \times 8.5}$ $L_{max} = 2760$ 22.95 $L_{max} = 120m$	Circuit Length = 46m $L_{max} = 120m$ $46 < 120$ Circuit satisfies the requirements of fault loop impedance.
1 Mark	1 Mark	1 Mark	1 Mark

QUESTION 5. (4 Marks)

Determine the maximum demand for the following 230V SINGLE Domestic Installation

34 x 50W down lights (Ai)

17 x double 10A socket outlets (Bi)

5 x single 10A socket outlets (Bi)

1 x 5 kW 230V cooktop (C)

1 x 4 kW 230V oven (C)

1 x 15A socket outlet (general purpose) (Bii)

1 x 20A socket outlet for 230V 16A air conditioner (D)

4 x permanently connected 120W ceiling fans (Ai)

2 x 10A socket outlets installed > 2.4m for 75W exhaust fans (Ai)

66.57A

Load Group	No of Points / Load	Calculation	Maximum Demand
Ai	34 lights 3A (first 20) 4 C fans 2 ex fans	40 points 2A (next 20 or part thereof)	5A
Aii			
Bi	17 DBI-10A 39 points 10A (first 20) 5 Single 10A 17 x 2 = 34	10A fuses here SA (next 20 or part thereof) Max Demand = 20A	15A
Bii	1 x 15A 1 point socket outlet	10A	
C	5kW CT 9kW Total (50% connected load)	$I = \frac{9000}{230} \times 0.5 = 19.6A$	19.6A
D	1 x 20A 16A Air Cond. (75% connected load)	$I = 16 \times 0.75 = 12A$ socket outlet	12A
E			
F			
G			
61.6A	Q/A	Maximum Demand	

Deduct 1
incorrect line
mark each

SECTION C - (Cont'd)

TOTAL = 4 mks

SECTION C – (Cont'd)

QUESTION 6. (7 Marks)

Determine the maximum demand for the following 400/230V three-phase MULTIPLE domestic installation, consisting of thirty (30) individual living units.

Electrical equipment associated with each individual (1) unit:

- 18 x 50W down lights (Ai)
- 10 x double 10A socket outlets (Bi)
- 3 x single 10A socket outlets (Bi)
- 1 x 10A socket outlet for 230V air conditioner (Bi)
- 2 x permanently connected 120W ceiling fans (Ai)

In addition to the load above, six (6) of the units have the following electrical loads.

- 1 x 5 kW 230V cooktop (C)
- 1 x 4 kW 230V oven (C)
- 1 x 4.8 kW electric storage hot water system (F)

The following communal load is also installed:

- 30 x 230V 100W bollards (balanced equally across each phase) (H)
- 9 x 230V 250W 4A Metal Halide outdoor lighting (three (3) circuits) (H)
- 8 x double 10A single phase socket outlets. (two (2) circuits) (I)

Load Group	No of Points /	Calculation	Red	White	Blue	Load
Ai	Highline	Column 4 10 l/u per φ	7.5	7.5	7.5	5A + 0.25A x 10 = 7.5A per φ
Bi	10A skt outlets	Column 4 10 l/u per φ	52.5	52.5	52.5	15A + 3.75A x 10 = 52.5A per φ
Bii						
C	9kW Cooking	Column 3 2 l/u per φ	15	15	15	15A per φ which is only 2 units per
E	4.8 kW O.P.H.W.	Column 3 2 l/u per φ	12	12	12	6A per l/u = 6A x 2 = 12A per φ
G						
H	30 bollard	10 bollard + 3 Metal Halide per φ	16.3	16.3	16.3	(10x100)/230 + 3 x 4A = 16.3A per φ
I	10A S.O.	8 x DBI 8 x 2 = 16 points over 2 circuits	15	15	15	Other answers are possible 8 x 2A = max 15A over two φ
Ji						
Jii						
K						
L						
M						
Maximum Demand						118.3 118.3 103.3

Use only the required load groups in the table below


Deduct 1 mark each
incorrect line

SECTION C - (Cont'd)



$$\text{MFL} = \frac{\text{MFL}}{\text{MFL}} = \frac{\text{Outlets}}{\text{Outlets}} = \frac{\text{Outlets}}{\text{Outlets}}$$

SECTION C – (Cont'd)


QUESTION 7. (3 Marks)



Using the diagram above, determine the current carrying capacity of the THREE phase 4mm² multi-core Cu V90 cable, which is installed flat on a perforated cable tray spaced from one other similar circuit.



A 400V three phase final sub circuit supplying a socket outlet is to be wired with 4mm² X90 four-core and earth cable. The circuit is protected by a 32A, type C circuit breaker. The voltage measured at the Sub Board is 391V. In order to comply with AS/NZS 3000 regarding voltage drop, what is the maximum allowable route length of the circuit?



1 Markuse 25mm² 135A

~~AS3008 Table 2(4) Item 6~~
~~Table 7 Column 18~~
~~16mm = 105A~~

T7 C118

T2(4) Item 6

c) Determine the minimum cable size

1 Mark

= 127A

~~= 99.1A~~
~~1.03 × 0.98~~
~~= 100~~

100


b) Determine the minimum required current capacity for each cable

Derating table No 26(2)	Derating factor: 1.03	1/2 Mark
Derating table No 28(2)	Derating factor: 0.98	1/2 Mark
Derating table No 28(1)	Derating factor: N/A	1/2 Mark
Derating table No 26(1)	Derating factor: 0.98	0.75

a) List any applicable de-rating table and derating factor for the circuit

A three pole 100A type 'C' circuit breaker will protect the circuit.

A 400V THREE phase consumer main is to be enclosed in three single HD PVC conduits that will be installed touching under ground at a depth of 600mm. The ambient soil temperature is 20 °C. The circuit will be wired with 4 x single core X90 Cu cables.



QUESTION 9. (5 Marks)

SECTION C - (Cont'd)

SECTION C – (Cont'd)

QUESTION 10. (7 Marks)

Determine the maximum demand for the following 400V FACTORY Installation

Deduct 1
mark each
incorrect line

10 x double 10A socket outlets (Bi)

6 x hi bay metal halide lamps @ 3.5A each (A)

30 x fluorescent lamps @ 0.4A each (A)

3 x 20A three phase socket outlets (Biii)

3 x 15A three phase socket outlets (Biii)


2 x 400V single phase welders @ 20A each (H)

2 x 25A single phase motors (D)

Load Group	Points / Load	Calculation	Red	White	Blue
A	Lighting 30 fluro 6 Hi Bay	$30/3 = 10 \text{ per } \phi$ $10 \times 0.4 = 4\text{A}$ $6/3 = 2 \text{ per } \phi$ $3.5 \times 2 = 7\text{A}$	11	11	11
Bi	10A skts 10x2 = 20 points	$1000 + (750 \times 7) = 27.2\text{A}$ (8 points) $1000 + (750 \times 5) = 20.6\text{A}$ (6 points) $1000 + (750 \times 5) = 20.6\text{A}$ (6 points)	27.2	20.6	20.6
Bii					
Biii	3 x 20A 3φ 3 x 15A 3φ	FLC x 20 = 20A per φ + 75% x (20 x 2) = 30A per φ + 75% x (15 x 3) = 33.8A per φ	83.8	83.8	83.8
C					
D	2 x 25A 1φ Motors	FLC Largest = 25A 75% x 25A = 18.8A	43.8		
E					
F					
G					
H	2 x 400V 1φ Welders	FLC highest two 20A per welder over 2φ		40	40
Maximum Demand			165.8		

OTAFENSW

* Must use He 16A (B's)



The following diagram shows a main switch board in a domestic installation. The consumer mains include an active, neutral and main earth from the earth electrode. The installation condition of all final sub circuits is fully surrounded by thermal insulation. There are four (4) final sub circuits supplying socket outlets, wired with 2.5 mm^2 , multi-core, V90, Cu cables. It has been determined to use separate RCD's to provide the core, V90, Cu cables. It has been determined to use separate RCD's to provide the required earth leakage protection for the circuits. Complete all necessary active, neutral and earth connections for these four final sub-circuits on the wiring diagram below, ensuring the completed wiring complies with AS/NZS 3000.2007 and AS/NZS 3008.1-1999.

QUESTION 1. (5 Marks)

INSTRUCTION: The questions in this section require some simple drawing. Ensure that the drawing is neat and legible. The use of pencil on the drawing is acceptable in this section only.


SECTION D - (19 Marks)

End of Section C

SECTION D -- (cont)

QUESTION 2. (4 Marks)

A 20A type C circuit breaker with the following tripping characteristic is protecting a 230V circuit wired with 2.5 mm^2 , multi-core, V90, Cu cable. The circuit is supplying socket outlets. The fault loop impedance was measured at the extreme point on the circuit using a fault loop impedance instrument. The result was 1.6Ω at ambient conditions (ie 40°C). Answer the questions below. Show all working, and support your answer/s by marking the characteristic curve below.



- a) Calculate the fault current for an active to earth fault at the extreme point.

$$\begin{aligned} I_a &= \frac{U_0}{Z_{fl}} \\ &= \frac{230}{1.6} \\ &= 144 \text{ A} \end{aligned}$$

1 Mark

- b) Determine the breaker trip time using the fault condition indicated above.

$$\begin{aligned} I &= I_a \\ &= 144 \\ &\quad 20 \\ &= 7.2 \end{aligned}$$

2.5 s

1 Mark

- c) Does the circuit meet AS/NZS 3000 requirements for fault loop impedance? Why?

YES / NO No, disconnection time > 0.4 seconds

1 Mark

- e) Determine the maximum allowable resistance of the protective earth conductor.

AS3000:2007 Table 8.2 - maximum 0.5 Ohm.

1 Mark

1 Mark

- b) incorrectly connected

1 Mark

- a) correctly connected

1/2 Mark

The leads of the testing device are:

The main neutral should be:

1 Mark

- b) No fault

1/2 Mark


A reading of 0.9MΩ would indicate:

a) Connected to position 1

b) Disconnected as shown in position 2

The MEN link should be:

Circle the correct answer




The following diagram shows how the switchboard has been prepared, ready for testing the insulation resistance between active and earth of a single-phase lighting circuit. The circuit is protected by a 6A combined RCD/MCB. The lighting circuit has loads with dimmer control. Identify the correct setting for the insulation resistance tester by placing an "X" in the appropriate box and answer the four questions. The board is electrically isolated.

QUESTION 3. (4 Marks)**SECTION D - (cont)**

SECTION D – (cont)

QUESTION 4. (4 Marks)

Answer the question and complete the following table using the diagram below. A correct circuit connection test is being performed. Identify the correct setting for the test equipment by placing an “X” in the appropriate box. The board is electrically isolated.



Assuming the socket outlet is correctly connected, complete the table

Test Equipment Connection	Reading	
Earth to Active with socket outlet switch off	∞	1/2 Mark
Earth to Active with socket outlet switch on	≈ 10 Ω	1/2 Mark
Earth to Neutral with socket outlet switch off	≈ 5 Ω	1/2 Mark
Earth to Neutral with socket outlet switch on	≈ 5 Ω	1/2 Mark

Identify any fault indicated by a reading of 5 Ohms between the active and earth socket measured at the socket outlet:

Active - Neutral transposition

1 Mark

Groups with 10 or more outlets connected Applies where there are 10 or more outlets in an electrical installation. **Groups having a cross-sectional area of less than 2.5 mm²** excludes the connection of any socket-outlets to fused residual current devices. Table C8 applies to the connection of any socket-outlets to conductors having a cross-sectional area of less than 2.5 mm², except where they are used for the connection of a lighting point or a plug-in point of appropriate rating to not more than 150 W. **Groups with 2 or more outlets connected** Applies where connection of any socket-outlets to fixed and mobile equipment should be subdivided. **Groups with 2 or more outlets connected** applies to the connection of any socket-outlets to fixed and mobile equipment which may be used for specific items of electrical equipment such as television sets, stereos, etc., provided that the individual load of the equipment does not exceed 15 A. **Groups with 2 or more outlets connected** applies to the connection of any socket-outlets to fixed and mobile equipment which may be used for specific items of electrical equipment such as television sets, stereos, etc., provided that the individual load of the equipment does not exceed 15 A.

TABLE C8 TO TABLE C8
Cable cross-sectional areas and effective resistances resulting directly from spreading insulation methods used in conjunction with C5 and C6, & 2.5 mm² cross-sectional areas
Table C8 is a single-phase current density recommended for normal insulation of cable.
Figures for 1 m² and 10 mm² conductors are given primarily for detailed circuits
Supplying voltage which should be applied to satisfy normal requirements of these
high-voltage points on their connection impedance.
For the purposes of determining the number of points as the number of individual
separately in the combination.
A hopping demand is limited by the range elements which allows
for diversity in preparation of the circuit-breaker or the final source which allows
latching points. A limiter is needed to comprise two or more latching points.
Insulation, which is the number of points which is connected by flexible cords to the
concerned. Connections to the number of sections in which is subdivided as required
A separator is latching point. See Table C1 for rack systems and EBL lighting.
Insulation may be included in a floor for the connection of a
flexible lead.

Following table from AS3000.2007 determine the maximum recommended number of points permitted to be added onto an existing final sub circuit consisting of $8 \times 10A$ breaker outlets. The existing cable is $2.5mm^2$ multi-core Cu cable, protected by a $16A$ circuit breaker. There are three existing power circuits in the installation. Maximum current = $16A$. Connected load: $10A$ socket outlets $8 \times 2 @ 1A$ each = $16A$. Therefore no lighting points can be added.

SECTION D - (cont)

QUESTION 5. (2 Marks)